

Approved Materials List for Water and Sewer

Valve Boxes

Tyler Domestic HD or East Jordan	92C, 93D, 94E, 95E	30"-42" to 41"-64" Curb Box
Tyler Domestic HD or East Jordan	152-Ext	16" Curb Box Extension
Tyler Domestic HD or East Jordan	6850 (5-ft)	Main Line Valve Box

Frost Free Meter Pits/Yoke Fittings

Ford, Mueller, or AY McDonald	Frost Free Coil Pit	Meter Pit
Ford, Mueller, or AY McDonald	Adjustable Frost Free Coil Pit	Adjustable Meter Pit

*Shall include 4-ft pit with MIP compression fitting, ¾ FIP pack joint adaptor at connection to pit

**2-inch recessed hole for transmitter in locking lid, dual check, ball valve on setter.

***Application in parkway or concrete shall have ring and lid.

Ring/Lid

Mueller or approved equal	70097-98	Ring/Lid (2-inch recessed hole)
---------------------------	----------	---------------------------------

Other Meter Setters/Yoke

Ford or AY McDonald	Straight Line	Int. Setter with Comp Fittings
---------------------	---------------	--------------------------------

*Internal setter shall only be permitted written upon approval of Public Works Director prior to building permit application

Corp and Curb Valves

Ford	F-1000 (3/4 cc to 1" pack joint)	Corporation Stop Valve
Ford	B33-444 w/Pack Joint	Curb Valve

*1-inch min curb valves

Service Lines

High Density Polyethylene	1-inch min C.T.S. DR9	Service Lines
---------------------------	-----------------------	---------------

Compressions Fittings

Ford or AY	Pack Joint	CTS Compression Fittings
------------	------------	--------------------------

Main Line Valves

AVK/Mueller	C509/515	Resilient Wedge Gate Valve
-------------	----------	----------------------------

Fire Hydrants and Adaptors

Waterous	Pacer W-67, 5-ft bury	5-1/4" Dry Barrel Hydrant
Storz	4-1/2" with flapper	Pumper Nozzle Adaptor

Sanitary Sewer Fittings

PVC SDR 26	O-ring bell and spigot	Pipe and Fittings
Mission	Stainless steel band	Couplings
Predco	Epoxy	Taps